



STATE LEVEL WATER TESTING LABORATORY
TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
NO 31, 4th FLOOR, TWAD HOUSE, KAMARAJAR SALAI,
CHEPAUK, CHENNAI – 600005.

Phone: 044 - 28412098

E-mail: twadboardcwa2024@gmail.com

TEST REPORT

Doc. No: SLWTL/FORM/7.8/01

Report No.	TR/2026/293-02	Report Issue Date	24.07.2026	Page No. : 01 of 01
Invoice Details	3802/dt.20.07.2026/Rs.1180/-	ULR. No.	--	

Client Name & Address Contact No. / Email.ID	:	Sri Vidhya Academy International Residential School, Sokkanallur, Pattabiram Road, Chennai-600072.				
Sample Name	:	Water – Drinking Water				
Sample / Lab No.	:	2026/293				
Sample Source	:	Bore Well (RO Water)				
Sample Description	:	Clear Colorless Liquid				
Sample Submitted by	:	Customer				
Location & Date	:	In the School premises, Sokkanallur, Pattabiram Road, CH-72/dt.20.07.2026/11.00 AM				
Sample Container	:	Plastic – Good Condition				
Quantity of sample Received	:	2Litres	Sample Condition on Receipt	:	Good	
Sample Received on	:	20.07.2026	Environmental Condition	:	25.8°C	
Test Commenced on	:	20.07.2026	Test Completed on	:	24.07.2026	
S. No.	Parameters	Test Method	Unit	Result	Specification as per IS 10500: 2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	P. Alkalinity as CaCO ₃	IS 3025: Part 23: 2023	mg/L	Zero	--	--
2	Sodium as Na	IS 3025 (Part 45) : 1993	mg/L	21	--	--
3	Potassium as K	IS 3025 (Part 45) : 1993	mg/L	BDL(DL=2)	--	--
4	Manganese as Mn	IS 3025 (Part 59) : 2023	mg/L	BDL(DL=0.05)	0.1	0.3
5	Ammonia as NH ₃ - N	IS 3025 (Part 34) : 2019	mg/L	BDL(DL=0.05)	0.5	No relaxation
6	Nitrite as NO ₂	IS 3025 (Part 34/Sec-1) : 2023	mg/L	BDL(DL=0.005)	--	--
7	Phosphate as PO ₄	IS 3025 (Part 31/Sec-1) : 2022	mg/L	0.15	--	--
8	Oxygen Demand (Tidy's Test) 4 hrs. as O ₂	IS 3025 (Part 63) : 2007	mg/L	0.20	--	--

Remark: The tested sample conform to IS: 10500:2012 (RA: 2023) Drinking water Acceptable Limit / Permissible Limit specification with respect to above tested parameters of Chemical.

Note: 1. The test results relate only to the items tested.

2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.

3. The test items will not be retained for more than 15 days from the date of issue of the test report.

4. The result applied to the sample as received basis.

5. BDL: Below Detection Limit; DL: Detection Limit; NT: Not Tested (Bacteriologically unsafe).

MANAGER
SRI VIDHYA ACADEMY
INTERNATIONAL RESIDENTIAL SCHOOL
Sokkanallur, Pattabiram Road,
Chennai-600 072.
.....End of the Report.....

Authorised Signatory
K. Rengaraj - Assistant Water Analyst

Chief Water Analyst
TWAD Board, Chennai-5.

PRINCIPAL
SRI VIDHYA ACADEMY
International Residential School,
Sokkanallur, Pattabiram Road,
Chennai-600 072.